

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 6912-0065:164

Page 1 of 1

CATEGORY: Voice Communication Accessories

LISTEE: Faraday, 805 S. Maumee St., Tecumseh, MI 49286
Contact: Steven A. Blohm (517) 423-2111

DESIGN: Model MVP-600 audio adjunct system; Models AU-360-E, AU-360-EM, AU-367-E, AU-367-EM, AU-380-E, AU-380-EM, AU-387-E and AU-387-EM voice evacuation modules and Model MVP6-RM remote microphone station. Modules with EM suffix employed a microphone.

Model MVP-600 audio adjunct system consist of a signal generator, microphone, power amplifier, output transformer and switching and interface circuits to provide a voice-tone communication system adjunct for use with any separately listed compatible fire alarm control panel. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, NFPA 72 and in a manner acceptable to the authority having jurisdiction. Supervision is dependent upon the control unit. Power to the modules and the speakers circuits are intended to be supervised through the bell circuit of the control unit. All units except Model MVP6-RM are to be mounted adjacent to the fire alarm control panel. Model MVP6-RM must be installed in a listed back box.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a voice-tone communication unit when used with separately listed compatible fire alarm control units and speakers.

XLF: 6912-1408:108

05-21-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager